


# CERTIFICATE

Certified Passive House Component

Component-ID 0792sr03 valid until 31st December 2018

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany



Category: **Shower Water Heat Recovery**  
Manufacturer: **Dutch Solar Systems b.v.,  
Enschede,  
Niederlande**  
Product name: **DSS showerdrain channel WWHR model  
900/4**

steady-state efficiency
54 %
effective dead time
5 s
design flow rate
8 l/min

**This certificate was awarded based on the following criteria:**

Tested under standard boundary conditions<sup>1</sup> the system reduces the useful energy demand for shower by

$$44 \% \geq 30 \%$$

## Further properties

Pressure drop tap water at 8 l/min: 0.20 bar  
Connection tap water: 1/2" AG  
Connection waste water: DN 50



<sup>1</sup>Balanced flow rates, cold water temperature 10 °C, Temperature at shower head 40 °C, waste water temperature 35 °C, negligible pipe length, shower time 6 min, flow rate 8 l/min

Passive House  
efficiency class

phE

phD

phC

phB

phA

phA+

all climate zones



**CERTIFIED  
COMPONENT**

Passive House Institute