


CERTIFICATE

Certified Passive House Component

Component-ID 1005wi04 valid until 31st December 2017

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany




Category: **Window frame**
Manufacturer: **EuroFinestra s.a.s.,
Governolo di Roncoferraro,
Italy**
Product name: **ENERGY 68**


**This certificate was awarded based on the following
criteria for the warm, temperate climate zone**

Comfort $U_W = 0.98 \leq 1.00 \text{ W}/(\text{m}^2 \text{ K})$
 $U_{W,\text{installed}} \leq 1.05 \text{ W}/(\text{m}^2 \text{ K})$
with $U_g = 0.90 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene $f_{Rsi=0.25} \geq 0.65$



warm, temperate climate



**CERTIFIED
COMPONENT**

Passive House Institute

Passive House
efficiency class

phE


phD

phC


phB

phA


www.passivehouse.com



Calculation model



Isothermal



Description

Timber-cork frame (fir 0,11 W/mK, cork 0,04 W/mK). Frame width: 68mm. Glazing: 2/0,38/2-11-4-11-2/0,38/2. Spacer: SwissSpacer Ultimate. Secondary seal: Butyl.

Explanation





The window U-values were calculated for the test window size of 1.23 m × 1.48 m with $U_g = 0.90$ W/(m² K). If a higher quality glazing is used, the window U-values will improve as follows:

Glazing	$U_g =$	0.90	0.80	0.70	0.64	W/(m ² K)
		↓	↓	↓	↓	
Window	$U_W =$	0.98	0.91	0.83	0.79	W/(m ² K)

Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.


Further information relating to certification can be found on www.passivehouse.com and passipedia.org.

Frame values		Frame width b_f mm	U -value frame U_f W/(m ² K)	Ψ -glass edge Ψ_g W/(m K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Top	(to) 	85	0.96	0.026	0.71
Side	(s) 	85	0.96	0.026	0.71
Bottom	(bo) 	85	1.00	0.026	0.71
Mullion flying	(fm) 	110	1.03	0.026	0.70
Spacer: SWISSPACER Ultimate			Secondary seal: Butyl		

Validated installations

Formwork blocks (operable)

$U_{Wall} = 0.25 \text{ W/(m}^2 \text{ K)}$




$\Psi_{install}$	W/(m K)
Top	0.008
Side	0.008
Bottom	0.016

$U_{W,installed} = 1.01 \text{ W/(m}^2 \text{ K)}$

Lightweight timber (operable)

$U_{Wall} = 0.24 \text{ W/(m}^2 \text{ K)}$




$\Psi_{install}$	W/(m K)
Top	0.010
Side	0.010
Bottom	0.023

$U_{W,installed} = 1.02 \text{ W/(m}^2 \text{ K)}$

Exterior insulation and finishing system (EIFS) (operable)

$U_{Wall} = 0.23 \text{ W/(m}^2 \text{ K)}$



$\Psi_{install}$	W/(m K)
Top	0.002
Side	0.002
Bottom	0.012

$U_{W,installed} = 1.00 \text{ W/(m}^2 \text{ K)}$

