


CERTIFICATE

Certified Passive House Component

Component-ID 0822wc03 valid until 31st Decembar 2017

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany




Category: **Window connection**
Manufacturer: **ISO-Chemie GmbH,
Aalen,
Germany**
Product name: **ISO-TOP WINFRAMER**

**This certificate was awarded based on the following
criteria for the cool, temperate climate zone**

Comfort $U_{W,installed} \leq 0.85 \text{ W}/(\text{m}^2 \text{ K})$
with $U_g = 0.70 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene $f_{Rsi=0.25} \geq 0.70$



Passive House
efficiency class

phE

phD

phC

phB

phA

cool, temperate climate




ph B




**CERTIFIED
COMPONENT**

Passive House Institute



Calculation model



Isothermal

Description

PHI Standard-frame thermal conductivity of representative material: 0,086 W/(mK) Pane thickness: 44 mm (4/16/4/16/4), rebate depth: 18 mm, spacer: SuperSpacer Tri-Seal

Explanation


The window U-values were calculated for the test window size of 1.23 m × 1.48 m with $U_g = 0.70$ W/(m² K). If a higher quality glazing is used, the window U-values will improve as follows:

Glazing	$U_g =$	0.70	0.64	0.58	0.52	W/(m ² K)
		↓	↓	↓	↓	
Window	$U_W =$	0.78	0.74	0.70	0.66	W/(m ² K)




Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on www.passivehouse.com and passipedia.org.

Frame values			Frame width b_f mm	U -value frame U_f W/(m ² K)	Ψ -glass edge Ψ_g W/(m K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Top	(to)		120	0.76	0.025	0.72
Side	(s)		120	0.76	0.025	0.72
Bottom	(bo)		145	0.79	0.025	0.72
Spacer: Super Spacer TriSeal / T-Spacer Premium				Secondary seal: Polysulfide		

Validated installations

Insulated formwork blocks		EIFS		Cavity wall (operable)	
					
$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)
Top	0.005	Top	0.009	Top	0.002
Side	0.005	Side	0.009	Side	0.002
Bottom	0.023	Bottom	0.032	Bottom	0.018
$U_{W,installed} = 0.81$ W/(m ² K)		$U_{W,installed} = 0.83$ W/(m ² K)		$U_{W,installed} = 0.80$ W/(m ² K)	

