


CERTIFICATE

Certified Passive House Component

Component-ID 1409sp01 valid until 31st December 2019

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category: **Edge-bond for low-E-glazing: Secondary seal**

Manufacturer: **Dow Silicones Belgium SPRL,
Seneffe, Belgium**

Product name: **DOWSIL™ 3364 Warm Edge IG Sealant**

This certificate was awarded based on the following criteria:

Depending on the climatic region, the spacer prevents high surface temperatures, which can cause mould. At least 3 out of the 7 reference frames fulfilled the spacer hygiene criteria for the relevant climatic region.

Hygiene $f_{Rsi} \geq 0.80$

The specific resistance of the spacer's edges is higher than the climate-independent minimum requirement.

Efficiency $R_E = 5.88 \text{ m K/W} \geq 3.50 \text{ m K/W}$

Type
Silicone
Height of sealing
4 / 6 mm
Thermal conductivity of sealing
0.190 W/(m K)

Passive House
efficiency class

phE

phD

phC

phB

phA

phA+

www.passivehouse.com

arctic climate



**CERTIFIED
COMPONENT**

Passive House Institute

Dow Silicones Belgium SPRL

Parc Industriel Zone C, Rue Jules Bordet, 7180 Seneffe, Belgium

☎ +32 64 88 85 93 | ✉ sebastien.dath@dow.com | 🌐 <http://www.dow.com> |

Description

Thermally improved secondary sealant based on silicone for the edge of insulating glass units.
Tested thickness of secondary seal: Windows: 4 mm, Curtain walls: 6 mm

Thermal conductivity: 0.190 W/(m K)




































Explanation

Sealants are categorized into different efficiency classes based on the resistance of their edges R_E . For the certification of secondary sealants, the PHI-phA-reference spacer with a height of 7 mm and a thermal conductivity of 0.2 W/(mK) is used.

A detailed report with the calculations is available from either the manufacturer or the Passive House Institute.

The Passive House Institute has defined global component requirements for seven climate regions. In principle, components that have been certified for climates with higher requirements can also be used in climates with lower requirements. This may be economically advantageous.

Further information regarding certification is available on www.passivehouse.com and www.passipedia.org.

Climate	Reference frames calculated with Silicone				
	Arctic ✓	Cool ✓	Cool temperate ✓	Warm temperate ✓	Warm ✓
Glass	Quadruple	Triple	Triple	Triple	Double
Glass package	4/12/3/12/3/12/4	6/18/2/18/6	6/16/6/16/6	6/16/6/16/6	6/16/6
Glass U-value	0.35 W/(m ² K)	0.52 W/(m ² K)	0.70 W/(m ² K)	0.70 W/(m ² K)	1.20 W/(m ² K)
Timber-aluminium integral frame					
U_f [W/(m ² K)]	0.48	0.62	0.73	0.87	1.03
Ψ_g [W/(m K)]	0.027	0.028	0.029	0.028	0.034
f_{Rsi} [-]	0.81 ✓	0.77 ✓	0.73 ✓	0.71 ✓	0.61 ✓
Timber-aluminium					
U_f [W/(m ² K)]	0.54	0.57	0.75	0.97	1.19
Ψ_g [W/(m K)]	0.028	0.029	0.030	0.030	0.037
f_{Rsi} [-]	0.77	0.75	0.70 ✓	0.67 ✓	0.55 ✓
Timber					
U_f [W/(m ² K)]	0.51	0.53	0.78	0.86	0.99
Ψ_g [W/(m K)]	0.025	0.027	0.028	0.028	0.034
f_{Rsi} [-]	0.79	0.78 ✓	0.74 ✓	0.74 ✓	0.63 ✓
Vinyl					
U_f [W/(m ² K)]	0.70	0.75	0.82	1.02	1.16
Ψ_g [W/(m K)]	0.029	0.031	0.032	0.033	0.039
f_{Rsi} [-]	0.79	0.77 ✓	0.71 ✓	0.73 ✓	0.62 ✓
Aluminium					
U_f [W/(m ² K)]	0.60	0.61	0.71	0.73	1.17
Ψ_g [W/(m K)]	0.029	0.031	0.033	0.033	0.041
f_{Rsi} [-]	0.80 ✓	0.80 ✓	0.77 ✓	0.77 ✓	0.64 ✓
Curtain wall timber					
U_f [W/(m ² K)]	0.60	0.65	0.66	0.71	1.11
Ψ_g [W/(m K)]	0.037	0.036	0.038	0.038	0.050
f_{Rsi} [-]	0.78	0.76 ✓	0.73 ✓	0.73 ✓	0.60 ✓
Curtain wall aluminium					
U_f [W/(m ² K)]	0.67	0.73	0.75	0.79	1.33
Ψ_g [W/(m K)]	0.042	0.041	0.044	0.045	0.065
f_{Rsi} [-]	0.85 ✓	0.83 ✓	0.81 ✓	0.81 ✓	0.70 ✓

