


CERTIFICATE

Certified Passive House Component

Component-ID 1467cw02 valid until 31st December 2020

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany




Category: **Curtain Wall**
Manufacturer: **GlasCurtain Inc.,
Calgary,
Canada**
Product name: **ThermPH**

**This certificate was awarded based on the following
criteria for the cold climate zone**

Comfort $U_{CW} = 0.60 \leq 0.60 \text{ W}/(\text{m}^2 \text{ K})$
 $U_{CW, \text{installed}} \leq 0.65 \text{ W}/(\text{m}^2 \text{ K})$
with $U_g = 0.52 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene $f_{Rsi=0.25} \geq 0.75$



Passive House
efficiency class

phE

phD

phC

phB

phA

phA+


www.passivehouse.com

cold climate



**CERTIFIED
COMPONENT**

Passive House Institute



Description

Fibre-glass curtain wall with EPS-insulation (0.031 W/(mK)). Fibre glass glass support, all values determined via 3D-FEM simulation. Pane thickness: 56 mm (6/19/6/19/6), rebate depth: 12 mm, spacer: SuperSpacer Tri-Seal with silicone (DOWSIL) secondary seal

Explanation

The element U-values were calculated for the test element size of 1.20 m × 2.50 m with $U_g = 0.70 \text{ W}/(\text{m}^2 \text{ K})$. If a higher quality glazing is used, the element U-values will improve as follows:

| | | | | | | |
|---------|----------|------|------|------|------|----------------------|
| Glazing | $U_g =$ | 0.52 | 0.54 | 0.58 | 0.60 | W/(m ² K) |
| | | ↓ | ↓ | ↓ | ↓ | |
| Element | U_{CW} | 0.60 | 0.62 | 0.66 | 0.68 | W/(m ² K) |

Transparent building components are sorted into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components that have been certified for climate zones with higher thermal requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on www.passivehouse.com and passipedia.org.




| Frame values | | | Frame width b_f mm | U -value frame U_f^1 W/(m ² K) | Ψ -panel edge Ψ_g W/(m K) | Temp. Factor $f_{Rsi=0.25}$ [-] |
|------------------|-------|--|----------------------------|---|---|---------------------------------------|
| Top fixed | (tof) | | 64 | 0.76 | 0.028 | 0.80 |
| Side fixed | (sf) | | 64 | 0.76 | 0.028 | 0.80 |
| Bottom fixed | (bof) | | 64 | 0.76 | 0.028 | 0.80 |
| Mullion fixed | (m) | | 64 | 0.62 | 0.029 | 0.81 |
| Transom fixed | (tf) | | 64 | 0.62 | 0.029 | 0.81 |

Spacer: Super Spacer TriSeal / T-Spacer Premium

Secondary seal: DOWSIL™ 3364 Warm Edge IG Sealant

Thermal glass carrier bridge ² $\chi_{GT} = 0.007$ W/K

Validated installations



¹ Includes $\Delta U = 0.10$ W/(m² K). Determined through 3D - FEM Simulation

² Determined through 3D - FEM Simulation . Glass carrier type : Non-Metallic Glass Carrier with Screws

