


CERTIFICATE

Certified Passive House Component

Component-ID 0631wi02 valid until 31st December 2020

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany




Category: **Window Frame**
Manufacturer: **Harbin Sayyas Windows Stock Co. Ltd.,
Wanggang Town Nangang Distr.
Harbin,
China**
Product name: **Sayyas PASSIVAPLUS**

This certificate was awarded based on the following criteria for the cold climate zone

Comfort $U_W = 0.60 \leq 0.60 \text{ W}/(\text{m}^2 \text{ K})$
 $U_{W,\text{installed}} \leq 0.65 \text{ W}/(\text{m}^2 \text{ K})$
with $U_g = 0.52 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene $f_{Rsi=0.25} \geq 0.75$



Passive House
efficiency class

phE

phD

phC

phB

phA

www.passivehouse.com


cold climate



phA

**CERTIFIED
COMPONENT**

Passive House Institute



Description

Timber window frame (0,11 W/(mK)) wit GRP cladding, insulated by EPS (0,031 W/(mK)). Glazing: 5/18/5/18/5, Glass intersection: 15 mm. Pane thickness: 51 mm (5/18/5/18/5), Rebate depth: 15 mm.

Explanation





The window U-values were calculated for the test window size of 1.23 m × 1.48 m with $U_g = 0.52 \text{ W}/(\text{m}^2 \text{ K})$. If a higher quality glazing is used, the window U-values will improve as follows:

Glazing	$U_g =$	0.52	0.70	0.64	0.58	W/(m ² K)
		↓	↓	↓	↓	
Window	$U_W =$	0.60	0.73	0.69	0.65	W/(m ² K)




Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on www.passivehouse.com and passipedia.org.

Frame values			Frame width b_f mm	U -value frame U_f W/(m ² K)	Ψ -panel edge Ψ_g W/(m K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Top	(to)		100	0.59	0.024	0.77
Side	(s)		100	0.59	0.024	0.77
Bottom	(bo)		100	0.64	0.023	0.77
Mullion flying	(fm)		126	0.74	0.023	0.77
			Spacer: SWISSPACER Ultimate		Secondary seal: Polyurethan	

Validated installations

Formwork blocks (operable)		Lightweight timber (operable)		Exterior insulation and finishing system (EIFS) (operable)	
					
$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)
Top	0.007	Top	0.016	Top	0.005
Side	0.007	Side	0.016	Side	0.005
Bottom	0.009	Bottom	0.019	Bottom	0.014
$U_{W,installed} = 0.63$ W/(m ² K)		$U_{W,installed} = 0.65$ W/(m ² K)		$U_{W,installed} = 0.62$ W/(m ² K)	

