


CERTIFICATE

Certified Passive House Component

Component-ID 1402as00 valid until 31st December 2019

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category: Airtightness Systems | **Surface Air Sealing**

Manufacturer: **FINSA**
N-550, km. 57
15707 – Santiago de Compostela
A Coruña (Spain)

Product-System: **superPan Tech P5 VapourStop (12 mm)**

Description: System for air sealing the building fabric in framed construction

System Components: Wood composite boards:
superPan Tech P5 VapourStop (12 mm)
Air tightness tapes: SIGA Sicrall,
SIGA 60 Fentrim 20 50/85

permeability

0.01 m³/(m²h) (±0.002)

instructions for use

coherent ✓

recommended
detailing

comprehensive ✓

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit area @ 50 Pa [m ³ /(h·m ²)]
A	≤ 0,10
B	≤ 0,18
C	≤ 0,25

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components

Adhering to these recommendations the system can greatly simplify the execution of an airtight building fabric. The complete Certification Report may also be downloaded at

www.passiv.de.



**CERTIFIED
COMPONENT**

Passive House Institute