

CERTIFICATE

Certified Passive House Component


Component-ID 0967ac03 valid until 31st December 2018

Passive House Institute

Dr. Wolfgang Feist

64283 Darmstadt

Germany



Category: Airtightness Systems | **Window Connection**

Manufacturer: **Iso-Chemie GmbH**
Röntgenstraße 12
73431 Aalen, Germany

Product-System: **ISO-BLOCO ONE (3-18 mm)**

Description: System for airtight and thermal bridge reduced window installation

System Components: Multi-Function Sealing Strips „ISO-BLOCO ONE“
In-Front-Of-Wall Installation System
„ISO-TOP WINFRAMER“

permeability

0,17 m³/(mh) (±0,01)

instructions for use

coherent ✓

recommended
detailing

comprehensive ✓

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit length @ 50 Pa [m ³ /(hm)]
A+	≤ 0,05
A	≤ 0,30
B	≤ 0,50
C	≤ 0,80

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components [ISO-BLOCO ONE Manual .pdf](#)
Adhering to these recommendations the system can greatly simplify the execution of an airtight window connection. The complete Certification Report may also be downloaded at www.passiv.de.



**CERTIFIED
COMPONENT**

Passive House Institute