


CERTIFICATE

Certified Passive House Component

Component-ID 1051as03 valid until 31st December 2018

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category: Airtightness Systems | **Surface Air Sealing**

Manufacturer: **SIGA Cover AG**
Rüt mattstrasse 7
CH-6017 Ruswil, Schweiz

Product-System: **SIGA Majrex**

Description: System for surface air sealing

System Components: Airtight membrane „SIGA Majrex“
Self-adhesive Tape „SIGA Sicrall 60“
Self-adhesive Tape „SIGA Fentrim 20 50/85“

permeability

0.02 m³/(hm²) (±0.002)

instructions for use

coherent ✓

recommended
detailing

comprehensive ✓

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit area @ 50 Pa [m ³ /(hm ²)]
phA	≤ 0.10
phB	≤ 0.18
phC	≤ 0.25

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components.

Adhering to these recommendations the system can greatly simplify the execution of an airtight building fabric. The complete Certification Report may also be downloaded at www.passiv.de.



**CERTIFIED
COMPONENT**

Passive House Institute