


# CERTIFICATE

Certified Passive House Component

Component-ID 0731wi02 valid until 31st December 2018

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany




Category: **Window Frame**  
Manufacturer: **FANZOLA SNC,  
Rosta,  
Italy**  
Product name: **NULL FENSTER**

**This certificate was awarded based on the following  
criteria for the cold climate zone**

Comfort  $U_W = 0.60 \leq 0.60 \text{ W}/(\text{m}^2 \text{ K})$   
 $U_{W,\text{installed}} \leq 0.65 \text{ W}/(\text{m}^2 \text{ K})$   
with  $U_g = 0.52 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene  $f_{Rsi=0.25} \geq 0.75$



Passive House  
efficiency class

phE

phD

phC

phB


phA

cold climate



**CERTIFIED  
COMPONENT**

Passive House Institute



### Description

Timber frame (Spruce 0.11 W/(mK)) with insulation of dense polyurethane foam (0.086 W/(mK)) and cork (0.04 W/(mK)). Glazing thickness: 4/18/4/18/4. Spacer: SWISSPACER Ultimate.

### Explanation





The window U-values were calculated for the test window size of 1.23 m × 1.48 m with  $U_g = 0.52$  W/(m<sup>2</sup> K). If a higher quality glazing is used, the window U-values will improve as follows:

Glazing	$U_g =$	0.52	0.70	0.64	0.58	W/(m <sup>2</sup> K)
		↓	↓	↓	↓	
Window	$U_W =$	0.60	0.71	0.67	0.64	W/(m <sup>2</sup> K)


Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.


The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.


Further information relating to certification can be found on [www.passivehouse.com](http://www.passivehouse.com) and [passipedia.org](http://passipedia.org).

Frame values			Frame width $b_f$ mm	$U$ -value frame $U_f$ W/(m <sup>2</sup> K)	$\Psi$ -panel edge $\Psi_g$ W/(m K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Top	(to)		130	0.57	0.024	0.77
Side	(s)		130	0.57	0.024	0.77
Bottom	(bo)		127	0.58	0.024	0.77
Mullion flying	(fm)		142	0.90	0.025	0.77
			Spacer: SWISSPACER Ultimate		Secondary seal: Polysulfide	

### Validated installations

Formwork blocks (operable)	
	
$\Psi_{install}$	W/(m K)
Top	-0.004
Side	-0.004
Bottom	0.003
$U_{W,installed} = 0.59 \text{ W/(m}^2 \text{ K)}$	

Lightweight timber (operable)	
	
$\Psi_{install}$	W/(m K)
Top	0.019
Side	0.019
Bottom	0.022
$U_{W,installed} = 0.65 \text{ W/(m}^2 \text{ K)}$	

Exterior insulation and finishing system (EIFS) (operable)	
	
$\Psi_{install}$	W/(m K)
Top	-0.006
Side	-0.006
Bottom	0.002
$U_{W,installed} = 0.58 \text{ W/(m}^2 \text{ K)}$	

