
CERTIFICATE

Certified Passive House Component Component-ID 1022cw03 valid until 31st December 2025 Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt Germany





Category:	Curtain Wall
Manufacturer:	RAICO Bautechnik GmbH,
	Pfaffenhausen,
	Germany
Product name:	THERM+50 FS-I


This certificate was awarded based on the following criteria for the cool, temperate climate zone

Comfort	$U_{CW} = 0.79$	\leq	0.80 W/(m ² K)
	$U_{CW, \text{installed}}$	\leq	0.85 W/(m ² K)
	with U_g	=	$0.70 W/(m^2 K)$

Hygiene $f_{Rsi=0.25}$ \geq 0.70







Description

Construction: Steel aluminum curtain wall with insulation inside the glazing rebate (0.038 W/(mK)) with aluminium foil applied on the inside. Pane thickness: 44 mm (4/16/4/16/4), rebate depth: 13 mm, spacer: SWISSPACER Ultimate. Different versions of pressureplate, coverstrip and insulating material are available and have been evaluated. These values can be provided by the system provider and the PHI on request. The glazing was calculated with a 3 mm secondary seal. As it is often the case that this is thicker, today the calculation is carried out with a 6 mm secondary seal. This leads to a higher glazing edge thermal bridge, which can also be estimated by way of the spacer certificates: www.passivhauskomponenten.org / glazing edge bonds. The higher rates of heat loss can be compensated for by using e. g. improved glazing.

Explanation

The element U-values were calculated for the test element size of $1.20 \text{ m} \times 2.50 \text{ m}$ with $U_g = 0.70 \text{ W/(m^2 K)}$. If a higher quality glazing is used, the element U-values will improve as follows:

Glazing	$U_g =$	0.70	0.64	0.58	0.52	W/(m ² K)
		\downarrow	\downarrow	\downarrow	\downarrow	
Element	U_{CW}	0.79	0.73	0.68	0.62	$W/(m^2 K)$

Transparent building components are sorted into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components that have been certified for climate zones with higher thermal requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.


Further information relating to certification

can be found on www.passivehouse.com and passipedia.org.

Frame value	es		Frame width <i>b_f</i> mm	<i>U</i> -value frame <i>U</i> f ¹ W/(m ² K)	$arPsi$ -glazing edge $arPsi_g$ W/(m K)	Temp. Factor f _{Rsi=0.25} [-]
Mullion fixed	(0M1)	-	50	0.90	0.031	0.78
Transom fixed	(0T1)	+	50	0.93	0.030	0.78
Transom 1 casement	(1T1)	4	90	1.07	0.028	0.68
Bottom fixed	(FB1)	1	50	0.78	0.030	0.78
Top fixed	(FH1)	T.	50	0.78	0.030	0.78
Lateral fixed	(FJ1)	-	50	0.78	0.030	0.78
	Spa	icer: SW	ISSPACER Ultimate	e Seco	ndary seal: Polysulfic	de

Thermal glass carrier bridge² χ_{GT} = 0.004 W/K

Validated installations



¹Includes ΔU = 0.21 W/(m² K). Determined through 3D FEM simulation ²Determined through 3D FEM simulation. Glass carrier type: Non-metallic

www.passivehouse.com