


# CERTIFICATE

Certified Passive House Component

Component-ID 1456cw03 valid until 31st December 2021

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany




Category: **Curtain Wall**  
Manufacturer: **Beijing Wuddy Building Technology Co. Ltd. China, Beijing, China**  
Product name: **ECO 170 CURTAIN WALL**

**This certificate was awarded based on the following criteria for the cool, temperate climate zone**

Comfort  $U_{CW} = 0.80 \leq 0.80 \text{ W}/(\text{m}^2 \text{ K})$   
 $U_{CW, \text{installed}} \leq 0.85 \text{ W}/(\text{m}^2 \text{ K})$   
with  $U_g = 0.70 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene  $f_{Rsi=0.25} \geq 0.70$



cool, temperate climate



**CERTIFIED COMPONENT**

Passive House Institute

Passive House  
efficiency class

phE


phD

phC

phB

phA

[www.passivehouse.com](http://www.passivehouse.com)



### Description

Thermally separated curtain wall with PU-foam core (0.051 W/(mK)). Pane thickness: 49 mm (6/16/5/16/6), rebate depth: 16 mm, spacer: SWISSPACER Ultimate with butyl as secondary seal

### Explanation









The element U-values were calculated for the test element size of 1.20 m × 2.50 m with  $U_g = 0.70$  W/(m<sup>2</sup> K). If a higher quality glazing is used, the element U-values will improve as follows:

Glazing	$U_g =$	0.70	0.64	0.62	0.58	W/(m <sup>2</sup> K)
		↓	↓	↓	↓	
Element	$U_{CW}$	0.80	0.74	0.72	0.69	W/(m <sup>2</sup> K)




Transparent building components are sorted into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components that have been certified for climate zones with higher thermal requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on [www.passivehouse.com](http://www.passivehouse.com) and [passipedia.org](http://passipedia.org).

Frame values			Frame width $b_f$ mm	$U$ -value frame $U_f^1$ W/(m <sup>2</sup> K)	$\Psi$ -panel edge $\Psi_g$ W/(m K)	Temp. Factor $f_{RSI=0.25}$ [-]
Top fixed	(tof)		90	0.08	0.034	0.78
Side fixed	(sf)		90	0.84	0.034	0.79
Bottom fixed	(bof)		90	0.82	0.034	0.78
Mullion fixed	(m)		90	0.84	0.035	0.80
Mullion 1 casement	(m1)		186	0.83	0.034	0.76
Corner	(ec)		294	0.52	0.038	0.82
Transom fixed	(tf)		90	0.83	0.034	0.79
Transom 1 casement	(t1)		186	0.83	0.034	0.76
Spacer: SWISSPACER Ultimate			Secondary seal: Butyl			

### Validated installations

Ventilated facade (fixed glazing)		Exterior insulation and finishing system (EIFS) (fixed glazed)		Cavity wall (fixed glazing)	
$U_{Wall} = 0.13 \text{ W/(m}^2 \text{ K)}$		$U_{Wall} = 0.14 \text{ W/(m}^2 \text{ K)}$		$U_{Wall} = 0.13 \text{ W/(m}^2 \text{ K)}$	
					
$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)
Top	0.022	Top	0.026	Top	0.022
Left	0.022	Left	0.022	Left	0.022
Right	0.022	Right	0.022	Right	0.022
Bottom	0.039	Bottom	0.037	Bottom	0.039
$U_{W,installed} = 0.83 \text{ W/(m}^2 \text{ K)}$		$U_{W,installed} = 0.83 \text{ W/(m}^2 \text{ K)}$		$U_{W,installed} = 0.83 \text{ W/(m}^2 \text{ K)}$	

<sup>1</sup>Includes  $\Delta U = 0.07 \text{ W/(m}^2 \text{ K)}$ . Determined through 3D - FEM Simulation

