
## CERTIFICATE

**Certified Passive House Component** 

Component-ID 2343sr00 valid until 31st December 2025

Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt Germany



Category: Drain water heat recovery

Manufacturer: **ZYPHO**, **SA**,

Vila Nova de Gaia,

**Portugal** 

Product name: **ZYPHO Slim 50 DW** 

## This certificate was awarded based on the following criteria:

Tested under standard boundary conditions<sup>1</sup> the system reduces the useful energy demand for shower by

44% > 30%

## **Further properties**

Pressure drop tap water at 8 l/min: 0.38 bar Connection tap water: 1/2" Connection waste water: DN 40 nominal efficiency

54%

effective dead time

5s

design flow rate

8 l/min



 $^1$ Balanced flow rates, cold water temperature 10 °C, Temperature at shower head 40 °C, waste water temperature 35 °C, negligible pipe length, shower time 6 min, flow rate 8 l/min

Passive House efficiency class

phE

| ph**D** 

ph**C** 

phB

phA

phA+

all climate zones

ph B

CERTIFIED
COMPONENT

Passive House Institute