

CERTIFICATE

Certified Passive House Component


Component-ID 1493as00 valid until 31st December 2025

Passive House Institute

Dr. Wolfgang Feist

64283 Darmstadt

Germany



Category: Airtightness Systems | **Surface Air Sealing**

Manufacturer: **pro clima**
MOLL bauökologische Produkte GmbH
Rheintalstr. 35-43
68723 Schwetzingen, Germany

Product-System: pro clima **AEROSANA VISCONN**

Description: System for surface air sealing

System Components: Airtight spray membrane „ **AEROSANA VISCONN** “
Self-adhesive Tape „ **CONTEGA SOLIDO SL** “

permeability

0.05 m³/(hm²) (±0.005)

instructions for use

coherent ✓

recommended
detailing

comprehensive ✓

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit area @ 50 Pa [m ³ /(hm ²)]
phA	≤ 0.10
phB	≤ 0.18
phC	≤ 0.25

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components.

Adhering to these recommendations the system can greatly simplify the execution of an airtight building fabric. The complete Certification Report may also be downloaded at www.passiv.de.



phA

**CERTIFIED
COMPONENT**

Passive House Institute