


CERTIFICATE

Certified Passive House Component

Component-ID 11514as00 valid until 31st December 2025

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category: Airtightness Systems | **Surface Air Sealing**

Manufacturer: **The A. Proctor Group Ltd**
The Haugh
Blairgowrie PH10 7ER
United Kingdom

Product-System: **Wraptite**

Description: System for surface air sealing

System Components: Airtight membrane „Wraptite“ (self-adhesive)
Self-adhesive Tape „Wraptite tape“

permeability

0.05 m³/(hm²) (±0.002)

instructions for use

coherent ✓

recommended
detailing

comprehensive ✓

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit area
	@ 50 Pa [m ³ /(hm ²)]
phA	≤ 0.10
phB	≤ 0.18
phC	≤ 0.25

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components.

Adhering to these recommendations the system can greatly simplify the execution of an airtight building fabric. The complete Certification Report may also be downloaded at www.passiv.de.



**CERTIFIED
COMPONENT**

Passive House Institute