

# CERTIFICATE

Certified Passive House Component


Component-ID 2391as00 valid until 31st December 2025

Passive House Institute

Dr. Wolfgang Feist

64283 Darmstadt

Germany



Category: Airtightness Systems | **Surface Air Sealing**

Manufacturer: **Ubbink France**  
**ZA la Malabry, 13 Rue de Bretagne**  
**44240 La Chapelle-sur-Erdre**  
**France**

Product-System: Hygro Vap

Description: System for surface air sealing

System Components: Airtight membrane „ Hygro Vap“  
Self-adhesive Tape „Adhésif Ubbink intérieur“ and  
“Adhésif Ubbink extérieur“  
Cartridge glue „Colle d'étanchéité pare-vapeur  
Ubbink“

permeability

**0.03 m<sup>3</sup>/(hm<sup>2</sup>) (±0.004)**

instructions for use

coherent ✓

recommended  
detailing

comprehensive ✓

**This certificate was awarded based on the following criteria:**

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit area @ 50 Pa [m <sup>3</sup> /(hm <sup>2</sup> )]
phA	≤ 0.10
phB	≤ 0.18
phC	≤ 0.25

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components.  
Adhering to these recommendations the system can greatly simplify the execution of an



**CERTIFIED  
COMPONENT**

Passive House Institute