
CERTIFICATE

Certified Passive House Component Component-ID 2428sr00 valid until 31st December 2026 Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt Germany



phA

phA+

Category:	Drain water heat recovery
Manufacturer:	ACO Passavant GmbH,
	Philippsthal,
	Germany
Product name:	ACO ShowerDrain X2.1

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions¹ the system reduces the useful energy demand for shower by

$$36\% \ge 30\%$$

Further properties

Pressure drop tap water at 8 l/min:	0.13 bar
Connection tap water:	1/2" AG
Connection waste water:	DN50

¹Balanced flow rates, cold water temperature 10 ℃, Temperature at shower head 40 ℃, waste water temperature 35 ℃, negligible pipe length, shower time 6 min, flow rate 8 l/min

Passive House phE phD phC phB







www.passivehouse.com