

CERTIFICATE

Certified Passive House Component


Component -ID 1265ap00 valid until 31st December 2025

Passive House Institute

Dr. Wolfgang Feist

64283 Darmstadt

Germany



Category: Airtightness Systems | **Airtight penetrations**

Manufacturer: **Eisedicht GmbH**
Industriestraße 3
32694 Dörentrup, Deutschland

Product(s): Eisedicht **TYVEK®** and **BUTYL-ALU**

Description: Sealing collars for airtight feed-through of cables and pipes

individual products: „Tyvek® D1, RGD 50, RGD 100, GD 24, RGD 180“
„Alu-Butyl D1, RGD 50, RGD 100, GD 24, RGD 180“
„M-Tec6 K Tyvek® multiple feed-through“
„M-Tec6 K Alu-Butyl multiple feed-through“

permeability

0,09 m³/(hm) (±0,004)

instructions for use

coherent ✓

recommended
detailing

comprehensive ✓

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions the system meets the listed requirements

Air permeability based on the circumference of the penetrations

Class	@ 50 Pa [m ³ /(hm)]
phA+	≤ 0,05
phA	≤ 0,30
phB	≤ 0,50
phC	≤ 0,80

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components.

Adhering to these recommendations the system can greatly simplify the execution of an airtight building fabric. The complete Certification Report may also be downloaded at www.passiv.de.



**CERTIFIED
COMPONENT**

Passive House Institute