

Certificate

valid until 31.12.2026

 **Passivhaus
Institut**
Dr. Wolfgang Feist
Rheinstraße 44/46
D-64283 Darmstadt

**Low Energy
Component:**

**Facade anchor
Allface Wall Bracket F5 / F5+**

**Hersteller: Allface Befestigungstechnologie GmbH
2544, Leobersdorf, AUSTRIA**

The following criteria were used in awarding this certificate:

Efficiency Criterion

In two typical applications^{*)}, the construction is

$$\Delta U_{WB} < 0,025 \quad \text{W/(m}^2\text{K)}$$

Comfort Criterion

The inner surface must be warm enough to prevent mould as well as uncomfortable down-draught and radiation losses.

$$\theta_{i,min} > 17,00 \quad ^\circ\text{C}$$

The following thermal data were determined:

Type	Component ID	thermal bridge coefficient χ [W/K]	minimum temperature of the inner surface $\theta_{i,min}$ [°C]
Fix Point F5+	0970fa03	0,0130	19,27
Sliding Point F5		0,0081	19,34

*) The criterion was validated on both, a row house and a school building

