


CERTIFICATE

Certified Passive House Component

Component-ID 1099wi03 valid until 31st December 2025

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany




Category: **Window Frame**
Manufacturer: **Wuhu Conch Profiles and Science Co., Ltd, Wuhu, China**
Product name: **CONCH 90 passive Windows**

This certificate was awarded based on the following criteria for the cool, temperate climate zone

Comfort $U_W = 0.79 \leq 0.80 \text{ W}/(\text{m}^2 \text{ K})$
 $U_{W,\text{installed}} \leq 0.85 \text{ W}/(\text{m}^2 \text{ K})$
with $U_g = 0.70 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene $f_{Rsi=0.25} \geq 0.70$



Passive House
efficiency class

phE

phD

phC

phB

phA


www.passivehouse.com

cool, temperate climate



**CERTIFIED
COMPONENT**

Passive House Institute



Calculation model Isothermal

Description

Plastic frame with insulation (0.032 W/(mK)) Pane thickness: 47 mm (5/16/5/16/5), rebate depth: 22 mm

Explanation

The window U-values were calculated for the test window size of 1.23 m × 1.48 m with $U_g = 0.70$ W/(m² K). If a higher quality glazing is used, the window U-values will improve as follows:




Glazing	$U_g =$	0.70	0.52	0.58	0.64	W/(m ² K)
		↓	↓	↓	↓	
Window	$U_W =$	0.79	0.68	0.72	0.76	W/(m ² K)





Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on www.passivehouse.com and passipedia.org.

Validated installations

Exterior insulation and finishing system (EIFS) (operable)	Formwork blocks (operable)	Lightweight timber (operable)
$U_{\text{Wall}} = 0.13 \text{ W}/(\text{m}^2 \text{ K})$	$U_{\text{Wall}} = 0.15 \text{ W}/(\text{m}^2 \text{ K})$	$U_{\text{Wall}} = 0.13 \text{ W}/(\text{m}^2 \text{ K})$
		
Ψ_{install} W/(m K)	Ψ_{install} W/(m K)	Ψ_{install} W/(m K)
Top 0.002	Top 0.003	Top 0.010
Side 0.002	Side 0.003	Side 0.010
Bottom 0.021	Bottom 0.020	Bottom 0.014
$U_{W,\text{installed}} = 0.81 \text{ W}/(\text{m}^2 \text{ K})$	$U_{W,\text{installed}} = 0.82 \text{ W}/(\text{m}^2 \text{ K})$	$U_{W,\text{installed}} = 0.83 \text{ W}/(\text{m}^2 \text{ K})$

Frame values		Frame width b_f mm	U -value frame U_f W/(m ² K)	Ψ -glazing edge Ψ_g W/(m K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Flying Mullion (FM1)		146	0.79	0.025	0.79
Bottom (OB1)		151	0.80	0.026	0.75
Top (OH1)		120	0.79	0.026	0.74
Lateral (OJ1)		120	0.79	0.026	0.74
Spacer: SWISSPACER Ultimate		Secondary seal: Polysulfide			

