

# CERTIFICATE

Certified Passive House Component

ID: 0346cs03 valid until 31. December 2021

Passive House Institute

Dr. Wolfgang Feist

64342 Darmstadt

GERMANY



Category **Construction system | Lightweight construction**  
Manufacturer **Metsä Wood Deutschland GmbH**  
**Bremen**  
**GERMANY**

Product name **FinnFrame-Bausystem**

**This certificate for the cool, temperate climate zone was awarded based on the following criteria**

## Hygiene criterion

The minimum temperature factor of the interior surfaces is

$$f_{R_{si}=0,25m^2K/W} \geq 0.70$$

## Comfort criterion

The U-value of the installed windows is

$$U_{W,i} \leq 0.85 \text{ W}/(m^2K)$$

## Efficiency criteria

Heat transfer coefficient of building envelope

$$U \cdot f_{PHI} \leq 0.15 \text{ W}/(m^2K)$$

Temperaturfactor of opaque junctions

$$f_{R_{si}=0,25m^2K/W} \geq 0.86$$

Thermal bridge free design for key connection details

$$\Psi \leq 0.01 \text{ W}/(m^2K)$$

An airtightness concept for all components and connection details was provided.

cool, temperate climate



**CERTIFIED  
COMPONENT**

Passive House Institute

cool, temperate climate

[www.passivehouse.com](http://www.passivehouse.com)

## Determined values

<b>Thermal heat transfer coefficient</b>	<b>Dimension [m]</b>	<b>U-Wert [W/(m²K)]</b>
EW01 - External Wall	0.40	0.120
RO01 - Roof	0.34	0.140
BC01 - Basement Ceiling	0.37	0.150
FS01 - Floor Slab	0.43	0.132
EW02 - External Wall	0.53	0.149
BW01 - Basement Wall	0.48	0.161

  

<b>Thermal bridge coefficient opaque envelop</b>	<b>fRsi [-]</b>	<b>Ψ [W/(mK)]</b>
EWIW01 - External Wall Internal Wall	0.98	0.002
EWEC01 - External Wall Outer Corner	0.96	-0.042
FRRP01 - Flat Roof Roof Parapet	0.92	0.052
FRRP02 - Flat Roof Roof Parapet	0.91	0.088
EWEC01 - External Wall Outer Corner	0.95	-0.087
EWIC01 - External Wall Inner Corner	0.63	0.031
EWCE01 - External Wall internal CEiling	0.97	0.025
EWIW01 - External Wall Internal Wall	0.98	-0.002
FSIW01 - Floor Slab Internal Wall	0.99	0.001
FSEW01 - Floor Slab External Wall	0.33	-0.041
EWHB01 - External Wall Heated Basement Ceiling	0.33	0.019
EWHB02 - External Wall Heated Basement Ceiling	0.33	0.051