

Certificate

Certified Passive House Component

for cool, temperate climate, valid until 31.12.2025

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
GERMANY

Category: **Roof parapet connection**
 Manufacturer: **puren GmbH**
88662 Überlingen
 Product name: **purenit Attikaelement**

The following criteria were used in awarding this certificate:

Efficiency Criterion

The construction fulfils the requirement

$$\Psi \leq 0.010 \text{ W/(mK)}$$


Comfort Criterion

The inner surface must be warm enough to prevent mould as well as uncomfortable down-drought and radiation losses in relation to the standards.


$$\theta_{i,\min} \geq 17^{\circ}\text{C}$$

The following parameters were calculated:

Typ	thermal bridge coefficient Ψ [W/(mK)]	minimum inner surface temperature $\theta_{i,\min}$ [°C]
EIFS	0,005	17,8
RVF	0,006	17,3



Isothermal map EIFS



Isothermal map
Rear Ventilated Facade



CERTIFIED COMPONENT

Passive House Institute