
CERTIFICATE

Certified Passive House Component

Component-ID 2167sr00 valid until 31st December 2025

Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt Germany



Category: **Drain water heat recovery**Manufacturer: **Counter Flow Products B. V.,**

Holten, Netherlands

Product name: showerpipe VX 2100 (Turbo Rotator)

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions¹ the system reduces the useful energy demand for shower by

57% > 30%

Further properties

Pressure drop tap water at 8 l/min: 0.29 bar

Connection tap water: Rp 1/2" female

Connection waste water: DN 50

nominal efficiency

69%

effective dead time

5s

design flow rate

8 l/min



Passive House efficiency class

phE

ph**D**

ph**C**

ph**B**

ph**A**

ph**A**+

all climate zones

phA

CERTIFIED
COMPONENT

Passive House Institute

 $^{^1}$ Balanced flow rates, cold water temperature 10 °C, Temperature at shower head 40 °C, waste water temperature 35 °C, negligible pipe length, shower time 6 min, flow rate 8 l/min