


CERTIFICATE

Certified Passive House Component

Component-ID 2409wi03 valid until 31st December 2025

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany




Category: **Window Frame**
Manufacturer: **i2 Factory,
Salaspils district,
Latvia**
Product name: **sw i2**

**This certificate was awarded based on the following
criteria for the cool, temperate climate zone**

Comfort $U_W = 0.76 \leq 0.80 \text{ W/(m}^2 \text{ K)}$
 $U_{W, \text{installed}} \leq 0.85 \text{ W/(m}^2 \text{ K)}$
with $U_g = 0.70 \text{ W/(m}^2 \text{ K)}$

Hygiene $f_{Rsi=0.25} \geq 0.70$



Passive House
efficiency class

phE

phD

phC

phB

phA


cool, temperate climate



**CERTIFIED
COMPONENT**

Passive House Institute

www.passivehouse.com



Calculation model

Isothermal

Description

Aluminum-clad timber frame (Spruce/Fir, 0.11 W/(mK)), insulated by low-density wood-fibre board (0.05 & 0.04 W/(mK)) & PU insulation (0.03 W/(mK)). Pane thickness: 48 mm (4/18/4/18/4), rebate depth: 15 mm. Spacer: SWISSPACER Ultimate with polyurethane as secondary seal.

Explanation

The window U-values were calculated for the test window size of 1.23 m × 1.48 m with $U_g = 0.70$ W/(m² K). If a higher quality glazing is used, the window U-values will improve as follows:




Glazing	$U_g =$	0.70	0.64	0.58	0.52	W/(m ² K)
		↓	↓	↓	↓	
Window	$U_w =$	0.76	0.72	0.67	0.63	W/(m ² K)





Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on www.passivehouse.com and passipedia.org.

Validated installations

Exterior insulation and finishing system (EIFS) (operable)	Formwork blocks (operable)	Lightweight timber (operable)
$U_{\text{Wall}} = 0.13 \text{ W/(m}^2 \text{ K)}$	$U_{\text{Wall}} = 0.15 \text{ W/(m}^2 \text{ K)}$	$U_{\text{Wall}} = 0.12 \text{ W/(m}^2 \text{ K)}$
		
Ψ_{install} W/(m K)	Ψ_{install} W/(m K)	Ψ_{install} W/(m K)
Top -0.000	Top 0.002	Top 0.023
Side -0.000	Side 0.002	Side 0.023
Bottom 0.022	Bottom 0.022	Bottom 0.038
$U_{W,\text{installed}} = 0.78 \text{ W/(m}^2 \text{ K)}$	$U_{W,\text{installed}} = 0.78 \text{ W/(m}^2 \text{ K)}$	$U_{W,\text{installed}} = 0.84 \text{ W/(m}^2 \text{ K)}$

Frame values		Frame width b_f mm	U -value frame U_f W/(m ² K)	Ψ -glazing edge Ψ_g W/(m K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Flying Mullion	(FM1) 	110	0.73	0.022	0.73
Bottom	(OB1) 	86	0.87	0.022	0.71
Head	(OH1) 	86	0.66	0.023	0.74
Jamb	(OJ1) 	86	0.66	0.023	0.74
Spacer: SWISSPACER Ultimate			Secondary seal: Polyurethan		

