

CERTIFICATE

Certified Passive House Component


Component-ID 1891wc00 valid until 31st December 2025

Passive House Institute

Dr. Wolfgang Feist

64283 Darmstadt

Germany



Category: Airtightness Systems | **Window Connection**

Manufacturer: **Iso-Chemie GmbH**
Röntgenstraße 12
73431 Aalen, Germany

Product-System: **ISO-BLOCO HYBRATEC**
(80 / 4-20 and 95 / 4-20 mm)''

Description: System for airtight and thermal bridge reduced window installation

System Components: "ISO-TOP FLEX-ADHESIVE XP"
"ISO-TOP WINFRAMER"
"ISO-TOP FLEX-ADHESIVE WF"

permeability

0,46 m³/(mh) (±0,016)

instructions for use

coherent ✓

recommended detailing

comprehensive ✓

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit length
	@ 50 Pa [m ³ /(hm)]
A+	≤ 0,05
A	≤ 0,30
B	≤ 0,50
C	≤ 0,80

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components [ISO-BLOCO HYBRATEC.pdf](#)
Adhering to these recommendations the system can greatly simplify the execution of an airtight window connection. The complete Certification Report may also be downloaded at www.passiv.de.



CERTIFIED COMPONENT

Passive House Institute