

CERTIFICATE


Certified Passive House Component

Component-ID 1899as00 valid until 31st December 2025

Passive House Institute

64283 Darmstadt

Germany



Category: Airtightness Systems | **Surface Sealing**

Manufacturer: **Partel**
17 Claregalway Corporate Park
Claregalway, Co. Galway H91R85P
Ireland

Product-System: **Vara Fluid Spray**

Description: System for surface air sealing

System Components: Airtight Fluid Spray "Vara Fluid Spray"
Self-adhesive Tape „Vara Seal Tape“
Primer „Acraprime Spray“

permeability

0.00 m³/(hm²) (±0.003)

instructions for use

coherent ✓

recommended
detailing

comprehensive ✓

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit area @ 50 Pa [m ³ /(hm ²)]
phA	≤ 0.10
phB	≤ 0.18
phC	≤ 0.25

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components.

Adhering to these recommendations the system can greatly simplify the execution of an airtight building fabric. The complete Certification Report may also be downloaded at www.passiv.de.



**CERTIFIED
COMPONENT**

Passive House Institute