# CERTIFICATE

Certified Passive House Component Component-ID 1456cw03 valid until 31st December 2025 Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt Germany



Category:	Curtain Wall		
Manufacturer:	Beijing Wuddy Building Technology Co. Ltd. China,		
	Beijing, China		
Product name:	ECO 170 CURTAIN WALL		

## This certificate was awarded based on the following criteria for the cool, temperate climate zone

Comfort	$U_{CW}$ = 0.80 $U_{CW,installed}$ with $U_g$	<  <	0.80 W/(m <sup>2</sup> K) 0.85 W/(m <sup>2</sup> K) 0.70 W/(m <sup>2</sup> K)	
Hygiene	f <sub>Rsi=0.25</sub>	$\geq$	0.70	

phE





www.passivehouse.com

**Passive House** 

efficiency class



#### Description

Thermally seperated curtain wall with PU-foam core (0.051 W/(mK)). Pane thickness: 49 mm (6/16/5/16/6), rebate depth: 16 mm, spacer: SWISSPACER Ultimate with butyl as secondary seal

#### Explanation

The element U-values were calculated for the test element size of  $1.20 \text{ m} \times 2.50 \text{ m}$  with  $U_g = 0.70 \text{ W/(m^2 K)}$ . If a higher quality glazing is used, the element U-values will improve as follows:

Glazing	$U_g =$	0.70	0.64	0.62	0.58	W/(m <sup>2</sup> K)
		$\downarrow$	$\downarrow$	$\downarrow$	$\downarrow$	
Element	$U_{CW}$	0.80	0.74	0.72	0.69	W/(m <sup>2</sup> K)

Transparent building components are sorted into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components that have been certified for climate zones with higher thermal requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on www.passivehouse.com and passipedia.org.

Frame value	S		Frame width <i>b<sub>f</sub></i> mm	<i>U</i> -value frame <i>U</i> f <sup>1</sup> W/(m <sup>2</sup> K)	$arPsi$ -glazing edge $arPsi_g$ W/(m K)	Temp. Factor f <sub>Rsi=0.25</sub> [-]
Mullion	(0M1)	-	90	0.84	0.035	0.80
Transom	(0T1)		90	0.83	0.034	0.79
Mullion 1 casement	(1M1)	-78-	186	0.83	0.034	0.76
Transom 1 casement	(1T1)	\$	186	0.83	0.034	0.76
Corner	(CO1)	1	294	0.52	0.038	0.82
Bottom fixed	(FB1)	1	90	0.82	0.034	0.78
Top fixed	(FH1)	T	90	0.08	0.034	0.78
Lateral	(FJ1)	-	90	0.84	0.034	0.79
		Spacer:	SWISSPACER Ultim	late Se	econdary seal: Butyl	

### Validated installations



<sup>1</sup>Includes $\Delta U$  = 0.07 W/(m<sup>2</sup> K). Determined through 3D FEM simulation

www.passivehouse.com