


# CERTIFICATE

Certified Passive House Component

Component-ID 2267as00 valid until 31st December 2025

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany



Category: Airtightness Systems | **Surface Air Sealing**

Manufacturer: **SIGA Cover AG**  
Rüt mattstrasse 7  
CH-6017 Ruswil, Schweiz

Product-System: **SIGA Majvest 500 SA**

Description: System for surface air sealing

System Components: Airtight membrane „SIGA Majvest 500 SA“  
Self-adhesive Tape „SIGA Wigluv 100“  
Self-adhesive Tape „SIGA Trestard 150“

permeability

**0.01 m<sup>3</sup>/(hm<sup>2</sup>) (±0.004)**

instructions for use

coherent ✓

recommended  
detailing

comprehensive ✓

**This certificate was awarded based on the following criteria:**

Tested under standard boundary conditions the system meets the listed requirements

| Class | permeability<br>per unit area<br>@ 50 Pa<br>[m <sup>3</sup> /(hm <sup>2</sup> )] |
|-------|--|
| phA   | ≤ 0.10   |
| phB   | ≤ 0.18   |
| phC   | ≤ 0.25   |

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components.

Adhering to these recommendations the system can greatly simplify the execution of an airtight building fabric. The complete Certification Report may also be downloaded at [www.passiv.de](http://www.passiv.de).



**CERTIFIED  
COMPONENT**

Passive House Institute