
## CERTIFICATE

**Certified Passive House Component** Component-ID 2429sr00 valid until 31st December 2026 Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt Germany



phA

phA+

Category:	Drain water heat recovery
Manufacturer:	ACO Passavant GmbH,
	Philippsthal,
	Germany
Product name:	ACO ShowerDrain X2.2 PHI

## This certificate was awarded based on the following criteria:

Tested under standard boundary conditions<sup>1</sup> the system reduces the useful energy demand for shower by

$$49\% \ge 30\%$$

## **Further properties**

Pressure drop tap water at 8 l/min:0.25 barConnection tap water:1/2" AGConnection waste water:DN50

<sup>1</sup>Balanced flow rates, cold water temperature 10 ℃, Temperature at shower head 40 ℃, waste water temperature 35 ℃, negligible pipe length, shower time 6 min, flow rate 8 l/min

Passive House phE phD phC phB

www.passivehouse.com

nominal efficiency 60% effective dead time 5s design flow rate 8 l/min



